
RENO EVENING GAZETTE PROOF OF PUBLICATION

STATE OF NEVADA COUNTY OF WASHOE \$\) ss.

GERRY MURAN being first duly sworn, deposes and says: That she is the legal clerk of THE RENO EVENING GAZETTE, a daily newspaper published at Reno, in Washoe County, in the State of Nevada. That the notice. OF INTENT. of which a copy is hereto attached, was first published in said newspaper in its issue dated the the full period of ...1... days, the last publication thereof being in the issue dated the ... 13...day of....., 19.72... Signed Lerry Ilfuran. Subscribed and sworn to before me this



SUMMARY: Amends Washoe County Ordinance No. 193, Section 13.301, by changing the minimum size and specifications of cisterns and correcting a clerical error.

BILL NO. 313

ORDINANCE NO. 193

AN ORDINANCE OF THE COUNTY OF WASHOE PROVIDING MINIMUM STANDARDS TO SAFEGUARD LIFE, HEALTH, PROPERTY AND PUBLIC WELFARE BY REGULATING THE STORAGE, USE AND HANDLING OF DANGEROUS AND HAZARDOUS MATERIALS, SUBSTANCES, DEVICES AND PROCESSES, BY REGULATING THE MAINTENANCE OF BUILDINGS AND EQUIPMENT, BY PROVIDING FOR WEED ABATEMENT AND CONTROL, BY PROVIDING FOR THE ADMINISTRATION AND ENFORCEMENT OF SUCH REQUIREMENTS, PRESCRIBING PENALTIES FOR VIOLATIONS THEREOF, AND OTHER MATTERS PROPERLY RELATING THERETO.

THE BOARD OF COUNTY COMMISSIONERS OF THE COUNTY OF WASHOE DO ORDAIN:

SECTION 1.
Section 13.301(d)5 of Exhibit "A" to Ordinance No. 193 is hereby amended to provide as follows:

(d)

5. Fire hydrants shall contain two (2) two and one-half inch $(2\frac{1}{2}")$ outlets with national standard thread, seven and one-half $(7\frac{1}{2})$ thread per inch.

SECTION 2.
Section 13.301(g) of Exhibit "A" to Ordinance No. 193 is hereby amended to provide as follows:

(g) Cistern. Requirements, Location and Specifications.

In those areas not covered by fire hydrant requirements, a cistern shall be required every 1500 feet in any development.

Specifications - Size. Minimum size shall be 4000 gallons, 560 cubic feet, wall thickness shall be a minimum of 4 inches. Concrete shall be water proof type and attain a minimum of three thousand (3000) p.s.i. Manhole covers shall be a minimum of eighteen (18) inches by twenty-four (24) inches. Cistern shall be placed eighteen (18) inches or more below grade. Stand pipe shall be two (2) one-half (1/2) inch national standard with Fire Department hook-up extending twelve (12) inches above grade with a thirty-six (36) inch by eighteen (18) inch concrete half dome with the Fire Department connection and one (1) inch vent extending from the side of the concrete half dome. The one (1) inch vent must have male threads with appropriate caps and extend only into the air space of the tank. All piping must be galvanized type. The stand pipe must extend to the bottom of the tank and rest on a six (6) inch by six (6) inch iron plate. There must be a minimum of three (3) square inches of opening in one side of the pipe.

SECTION 3.

This amendment to Ordinance No. 193 shall be in full force and effect from and after its passage and approval as prescribed by NRS 244.105.

Proposed on the 6th day of November, 1972.

Proposed by Commissioner Coppa

Passed on the 27th day of November, 1972.

Vote:

Commissioners: Pagni, Coppa, McKissick, Nelson & Rusk Commissioners: None Commissioners: None

Ayes: Nays: Absent:

ATTEST: