



**NOTES:**

1. LETTERING IS WHITE. BACKGROUND IS PURPLE. SIGN "A" IS TO BE USED IN CONJUNCTION WITH ANY FENCED, RECLAIMED FACILITY; SIGN "B" TO BE USED WHEN ADVERTISING LANDSCAPE ISLANDS, MEDIANS, ETC.
2. SIGN MATERIAL SHALL BE 0.1-INCH THICK ALUMINUM. ALUMINUM SHALL BE DEGREASED BEFORE PAINTING. PAINT SHALL BE ALKYD ENAMEL.
3. MAXIMUM SPACING FOR ROADWAY LANDSCAPING SHALL BE 500 FEET.
4. SIGN "A" TO BE POSTED AT EACH ENTRANCE TO THE PROPERTY.
5. SIGN SIZE MAY BE SCALED DOWN TO 8"x12" WHEN REQUIRED BY THE COUNTY ENGINEER.

DATE	REVISIONS	 STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION RECLAIMED WATER SIGNAGE REQUIREMENTS	SECTION NUMBER: 300	
				DRAWING NUMBER: W-340
				DATE: 2/21/2022