

8/18/2020

Washoe County Water ResourcesCSD
PO Box 11130
Reno, NV 89502
Attn: Dylan Menes

OrderID: 20070821

Dear: Dylan Menes

This is to transmit the attached analytical report. The analytical data and information contained therein was generated using specified or selected methods contained in references, such as Standard Methods for the Examination of Water and Wastewater, online edition, Methods for Determination of Organic Compounds in Drinking Water, EPA-600/4-79-020, and Test Methods for Evaluation of Solid Waste, Physical/Chemical Methods (SW846) Third Edition.

The samples were received by WETLAB-Western Environmental Testing Laboratory in good condition on 7/23/2020. Additional comments are located on page 2 of this report.

If you should have any questions or comments regarding this report, please do not hesitate to call.

Sincerely,



Nick Ross
Operations Manager

SPARKS

475 E. Greg Street, Suite 119
Sparks, Nevada 89431
tel (775) 355-0202
fax (775) 355-0817
EPA LAB ID: NV00925 - ELAP No: 2523

ELKO

1084 Lamoille Hwy
Elko, Nevada 89801
tel (775) 777-9933
fax (775) 777-9933
EPA LAB ID: NV00926

LAS VEGAS

3230 Polaris Ave. Suite 4
Las Vegas, Nevada 89102
tel (702) 475-8899
fax (702) 622-2868
EPA LAB ID: NV00932

Western Environmental Testing Laboratory

Report Comments

Washoe County Water Resources CSD - 20070821

Specific Report Comments

Due to the sample matrix it was necessary to analyze the following at a dilution:

20070821-(001-004) Fluoride
20070821-(001-004) Nitrate Nitrogen
20070821-(001-004) Nitrite Nitrogen
20070821-004 Iron

The reporting limits have been adjusted accordingly.

Report Legend

- B -- Blank contamination; Analyte detected above the method reporting limit in an associated blank
- D -- Due to the sample matrix dilution was required in order to properly detect and report the analyte. The reporting limit has been adjusted accordingly.
- HT -- Sample analyzed beyond the accepted holding time
- J -- The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit. The reported result should be considered an estimate.
- K -- The TPH Diesel Concentration reported here likely includes some heavier TPH Oil hydrocarbons reported in the TPH Diesel range as per EPA 8015.
- L -- The TPH Oil Concentration reported here likely includes some lighter TPH Diesel hydrocarbons reported in the TPH Oil range as per EPA 8015.
- M -- The matrix spike/matrix spike duplicate (MS/MSD) values for the analysis of this parameter were outside acceptance criteria due to probable matrix interference. The reported result should be considered an estimate.
- N -- There was insufficient sample available to perform a spike and/or duplicate on this analytical batch.
- NC -- Not calculated due to matrix interference
- QD -- The sample duplicate or matrix spike duplicate analysis demonstrated sample imprecision. The reported result should be considered an estimate.
- QL -- The result for the laboratory control sample (LCS) was outside WETLAB acceptance criteria and reanalysis was not possible. The reported data should be considered an estimate.
- S -- Surrogate recovery was outside of laboratory acceptance limits due to matrix interference. The associated blank and LCS surrogate recovery was within acceptance limits
- SC -- Spike recovery not calculated. Sample concentration >4X the spike amount; therefore, the spike could not be adequately recovered
- U -- The analyte was analyzed for, but was not detected above the level of the reported sample reporting/quantitation limit. The reported result should be considered an estimate.

General Lab Comments

Per method recommendation (section 4.4), Samples analyzed by methods EPA 300.0 and EPA 300.1 have been filtered prior to analysis.

The following is an interpretation of the results from EPA method 9223B:

A result of zero (0) indicates absence for both coliform and Escherichia coli meaning the water meets the microbiological requirements of the U.S. EPA Safe Drinking Water Act (SDWA). A result of one (1) for either test indicates presence and the water does not meet the SDWA requirements. Waters with positive tests should be disinfected by a certified water treatment operator and retested.

Per federal regulation the holding time for the following parameters in aqueous/water samples is 15 minutes: Residual Chlorine, pH, Dissolved Oxygen, Sulfite.

SPARKS

475 E. Greg Street, Suite 119
Sparks, Nevada 89431
tel (775) 355-0202
fax (775) 355-0817
EPA LAB ID: NV00925 - ELAP No: 2523

ELKO

1084 Lamoille Hwy
Elko, Nevada 89801
tel (775) 777-9933
fax (775) 777-9933
EPA LAB ID: NV00926

LAS VEGAS

3230 Polaris Ave. Suite 4
Las Vegas, Nevada 89102
tel (702) 475-8899
fax (702) 622-2868
EPA LAB ID: NV00932

Western Environmental Testing Laboratory

Analytical Report

Washoe County Water ResourcesCSD

Date Printed: 8/18/2020

PO Box 11130

OrderID: 20070821

Reno, NV 89502

Attn: Dylan Menes

Phone: (775) 954-4612 Fax: NoFax

PO\Project: Swan Lake

Customer Sample ID: Swan Lake-Compton

Collect Date/Time: 7/23/2020 15:25

WETLAB Sample ID: 20070821-001

Receive Date: 7/23/2020 16:20

Analyte	Method	Results	Units	DF	RL	Analyzed	LabID
<u>General Chemistry</u>							
Total Phosphorous as P	SM 4500-P E	0.21	mg/L	1	0.020	7/28/2020	NV00925
Total Nitrogen	Calc.	2.6	mg/L	1	1.4	7/30/2020	NV00925
Total Dissolved Solids (TDS)	SM 2540C	1200	mg/L	1	25	7/24/2020	NV00925
<u>Microbiological Analyses</u>							
Fecal Coliform (MPN)	IDEXX Quant/Colilert-18	4.1	MPN/100ml	1	1.0	7/23/2020	NV00925
Total Coliform (MPN)	SM 9223B (Quantitray)	>2419.6	MPN/100ml	1	1.0	7/23/2020	NV00925
Escherichia Coli (MPN)	SM 9223B (Quantitray)	1.0	MPN/100ml	1	1.0	7/23/2020	NV00925
<u>Anions by Ion Chromatography</u>							
Fluoride	EPA 300.0	ND	D mg/L	2	0.60	7/25/2020	NV00925
Nitrate Nitrogen	EPA 300.0	ND	D mg/L	5	0.75	7/23/2020	NV00925
Nitrite Nitrogen	EPA 300.0	ND	D mg/L	5	0.30	7/23/2020	NV00925
<u>Flow Injection Analyses</u>							
Total Kjeldahl Nitrogen	EPA 351.2	2.5	mg/L	1	0.40	7/30/2020	NV00925
<u>Trace Metals by ICP-OES</u>							
Beryllium	EPA 200.7	ND	mg/L	1	0.0010	8/12/2020	NV00925
Boron	EPA 200.7	0.58	mg/L	1	0.10	8/12/2020	NV00925
Cadmium	EPA 200.7	ND	mg/L	1	0.0010	8/12/2020	NV00925
Chromium	EPA 200.7	ND	mg/L	1	0.0050	8/12/2020	NV00925
Copper	EPA 200.7	ND	mg/L	1	0.040	8/12/2020	NV00925
Iron	EPA 200.7	3.1	mg/L	1	0.10	8/12/2020	NV00925
Manganese	EPA 200.7	0.18	mg/L	1	0.010	8/12/2020	NV00925
Nickel	EPA 200.7	ND	mg/L	1	0.030	8/12/2020	NV00925
Zinc	EPA 200.7	ND	mg/L	1	0.020	8/12/2020	NV00925
<u>Trace Metals by ICP-MS</u>							
Arsenic	EPA 200.8	0.055	mg/L	1	0.0050	8/13/2020	NV00925
Lead	EPA 200.8	0.0028	mg/L	1	0.0025	8/13/2020	NV00925
Selenium	EPA 200.8	ND	mg/L	1	0.0050	8/13/2020	NV00925
<u>Sample Preparation</u>							
Trace Metals Digestion	EPA 200.2	W200812-1		1		8/12/2020	NV00925

DF=Dilution Factor, RL = Reporting Limit (minimum 3X the MDL), ND = Not Detected <RL or <MDL (if listed)

Page 3 of 8

SPARKS

475 E. Greg Street, Suite 119
 Sparks, Nevada 89431
 tel (775) 355-0202
 fax (775) 355-0817
 EPA LAB ID: NV00925 - ELAP No: 2523

ELKO

1084 Lamoille Hwy
 Elko, Nevada 89801
 tel (775) 777-9933
 fax (775) 777-9933
 EPA LAB ID: NV00926

LAS VEGAS

3230 Polaris Ave. Suite 4
 Las Vegas, Nevada 89102
 tel (702) 475-8899
 fax (702) 622-2868
 EPA LAB ID: NV00932

Customer Sample ID: Swan Lake- Pompe

Collect Date/Time: 7/23/2020 15:00

WETLAB Sample ID: 20070821-002

Receive Date: 7/23/2020 16:20

Analyte	Method	Results	Units	DF	RL	Analyzed	LabID
<u>General Chemistry</u>							
Total Phosphorous as P	SM 4500-P E	0.69	mg/L	1	0.020	7/28/2020	NV00925
Total Nitrogen	Calc.	1.9	mg/L	1	1.4	7/30/2020	NV00925
Total Dissolved Solids (TDS)	SM 2540C	1200	mg/L	1	25	7/24/2020	NV00925
<u>Microbiological Analyses</u>							
Fecal Coliform (MPN)	IDEXX Quant/Colilert-18	24.1	MPN/100ml	1	1.0	7/23/2020	NV00925
Total Coliform (MPN)	SM 9223B (Quantitray)	>2419.6	MPN/100ml	1	1.0	7/23/2020	NV00925
Escherichia Coli (MPN)	SM 9223B (Quantitray)	25.6	MPN/100ml	1	1.0	7/23/2020	NV00925
<u>Anions by Ion Chromatography</u>							
Fluoride	EPA 300.0	ND	D mg/L	2	0.60	7/25/2020	NV00925
Nitrate Nitrogen	EPA 300.0	ND	D mg/L	5	0.75	7/23/2020	NV00925
Nitrite Nitrogen	EPA 300.0	ND	D mg/L	5	0.30	7/23/2020	NV00925
<u>Flow Injection Analyses</u>							
Total Kjeldahl Nitrogen	EPA 351.2	1.9	mg/L	1	0.40	7/30/2020	NV00925
<u>Trace Metals by ICP-OES</u>							
Beryllium	EPA 200.7	ND	mg/L	1	0.0010	8/12/2020	NV00925
Boron	EPA 200.7	0.59	mg/L	1	0.10	8/12/2020	NV00925
Cadmium	EPA 200.7	ND	mg/L	1	0.0010	8/12/2020	NV00925
Chromium	EPA 200.7	ND	mg/L	1	0.0050	8/12/2020	NV00925
Copper	EPA 200.7	ND	mg/L	1	0.040	8/12/2020	NV00925
Iron	EPA 200.7	0.95	mg/L	1	0.10	8/12/2020	NV00925
Manganese	EPA 200.7	0.035	mg/L	1	0.010	8/12/2020	NV00925
Nickel	EPA 200.7	ND	mg/L	1	0.030	8/12/2020	NV00925
Zinc	EPA 200.7	ND	mg/L	1	0.020	8/12/2020	NV00925
<u>Trace Metals by ICP-MS</u>							
Arsenic	EPA 200.8	0.053	mg/L	1	0.0050	8/13/2020	NV00925
Lead	EPA 200.8	ND	mg/L	1	0.0025	8/13/2020	NV00925
Selenium	EPA 200.8	ND	mg/L	1	0.0050	8/13/2020	NV00925
<u>Sample Preparation</u>							
Trace Metals Digestion	EPA 200.2	W200812-1		1		8/12/2020	NV00925

SPARKS

475 E. Greg Street, Suite 119
 Sparks, Nevada 89431
 tel (775) 355-0202
 fax (775) 355-0817
 EPA LAB ID: NV00925 - ELAP No: 2523

ELKO

1084 Lamoille Hwy
 Elko, Nevada 89801
 tel (775) 777-9933
 fax (775) 777-9933
 EPA LAB ID: NV00926

LAS VEGAS

3230 Polaris Ave. Suite 4
 Las Vegas, Nevada 89102
 tel (702) 475-8899
 fax (702) 622-2868
 EPA LAB ID: NV00932

Customer Sample ID: Swan Lake-Jean
 WETLAB Sample ID: 20070821-003

Collect Date/Time: 7/23/2020 14:50

Receive Date: 7/23/2020 16:20

Analyte	Method	Results	Units	DF	RL	Analyzed	LabID
<u>General Chemistry</u>							
Total Phosphorous as P	SM 4500-P E	0.81	mg/L	1	0.020	7/28/2020	NV00925
Total Nitrogen	Calc.	2.0	mg/L	1	1.4	7/30/2020	NV00925
Total Dissolved Solids (TDS)	SM 2540C	1200	mg/L	1	25	7/24/2020	NV00925
<u>Microbiological Analyses</u>							
Fecal Coliform (MPN)	IDEXX Quant/Colilert-18	52.9	MPN/100ml	1	1.0	7/23/2020	NV00925
Total Coliform (MPN)	SM 9223B (Quantitray)	>2419.6	MPN/100ml	1	1.0	7/23/2020	NV00925
Escherichia Coli (MPN)	SM 9223B (Quantitray)	52.9	MPN/100ml	1	1.0	7/23/2020	NV00925
<u>Anions by Ion Chromatography</u>							
Fluoride	EPA 300.0	ND	D mg/L	2	0.60	7/25/2020	NV00925
Nitrate Nitrogen	EPA 300.0	ND	D mg/L	5	0.75	7/23/2020	NV00925
Nitrite Nitrogen	EPA 300.0	ND	D mg/L	5	0.30	7/23/2020	NV00925
<u>Flow Injection Analyses</u>							
Total Kjeldahl Nitrogen	EPA 351.2	1.9	mg/L	1	0.40	7/30/2020	NV00925
<u>Trace Metals by ICP-OES</u>							
Beryllium	EPA 200.7	ND	mg/L	1	0.0010	8/12/2020	NV00925
Boron	EPA 200.7	0.60	mg/L	1	0.10	8/12/2020	NV00925
Cadmium	EPA 200.7	ND	mg/L	1	0.0010	8/12/2020	NV00925
Chromium	EPA 200.7	ND	mg/L	1	0.0050	8/12/2020	NV00925
Copper	EPA 200.7	ND	mg/L	1	0.040	8/12/2020	NV00925
Iron	EPA 200.7	1.1	mg/L	1	0.10	8/12/2020	NV00925
Manganese	EPA 200.7	0.053	mg/L	1	0.010	8/12/2020	NV00925
Nickel	EPA 200.7	ND	mg/L	1	0.030	8/12/2020	NV00925
Zinc	EPA 200.7	ND	mg/L	1	0.020	8/12/2020	NV00925
<u>Trace Metals by ICP-MS</u>							
Arsenic	EPA 200.8	0.056	mg/L	1	0.0050	8/13/2020	NV00925
Lead	EPA 200.8	ND	mg/L	1	0.0025	8/13/2020	NV00925
Selenium	EPA 200.8	ND	mg/L	1	0.0050	8/13/2020	NV00925
<u>Sample Preparation</u>							
Trace Metals Digestion	EPA 200.2	W200812-1		1		8/12/2020	NV00925

DF=Dilution Factor, RL = Reporting Limit (minimum 3X the MDL), ND = Not Detected <RL or <MDL (if listed)

Page 5 of 8

SPARKS

475 E. Greg Street, Suite 119
 Sparks, Nevada 89431
 tel (775) 355-0202
 fax (775) 355-0817
 EPA LAB ID: NV00925 - ELAP No: 2523

ELKO

1084 Lamoille Hwy
 Elko, Nevada 89801
 tel (775) 777-9933
 fax (775) 777-9933
 EPA LAB ID: NV00926

LAS VEGAS

3230 Polaris Ave. Suite 4
 Las Vegas, Nevada 89102
 tel (702) 475-8899
 fax (702) 622-2868
 EPA LAB ID: NV00932

Customer Sample ID: Am-Flats-Spigot
 WETLAB Sample ID: 20070821-004

Collect Date/Time: 7/23/2020 14:35

Receive Date: 7/23/2020 16:20

Analyte	Method	Results	Units	DF	RL	Analyzed	LabID
General Chemistry							
Total Phosphorous as P	SM 4500-P E	0.27	mg/L	1	0.020	7/28/2020	NV00925
Total Nitrogen	Calc.	2.9	mg/L	1	1.4	7/30/2020	NV00925
Total Dissolved Solids (TDS)	SM 2540C	1100	mg/L	1	25	7/24/2020	NV00925
Microbiological Analyses							
Fecal Coliform (MPN)	IDEXX Quant/Colilert-18	13.2	MPN/100ml	1	1.0	7/23/2020	NV00925
Total Coliform (MPN)	SM 9223B (Quantitray)	>2419.6	MPN/100ml	1	1.0	7/23/2020	NV00925
Escherichia Coli (MPN)	SM 9223B (Quantitray)	6.3	MPN/100ml	1	1.0	7/23/2020	NV00925
Anions by Ion Chromatography							
Fluoride	EPA 300.0	ND	D mg/L	2	0.60	7/25/2020	NV00925
Nitrate Nitrogen	EPA 300.0	ND	D mg/L	5	0.75	7/23/2020	NV00925
Nitrite Nitrogen	EPA 300.0	ND	D mg/L	5	0.30	7/23/2020	NV00925
Flow Injection Analyses							
Total Kjeldahl Nitrogen	EPA 351.2	2.8	mg/L	1	0.40	7/30/2020	NV00925
Trace Metals by ICP-OES							
Beryllium	EPA 200.7	ND	mg/L	1	0.0010	8/12/2020	NV00925
Boron	EPA 200.7	0.53	mg/L	1	0.10	8/12/2020	NV00925
Cadmium	EPA 200.7	ND	mg/L	1	0.0010	8/12/2020	NV00925
Chromium	EPA 200.7	0.016	mg/L	1	0.0050	8/12/2020	NV00925
Copper	EPA 200.7	0.15	mg/L	1	0.040	8/12/2020	NV00925
Iron	EPA 200.7	32	mg/L	10	1.0	8/13/2020	NV00925
Manganese	EPA 200.7	1.2	mg/L	1	0.010	8/12/2020	NV00925
Nickel	EPA 200.7	ND	mg/L	1	0.030	8/12/2020	NV00925
Zinc	EPA 200.7	11	mg/L	1	0.020	8/12/2020	NV00925
Trace Metals by ICP-MS							
Arsenic	EPA 200.8	0.075	mg/L	1	0.0050	8/13/2020	NV00925
Lead	EPA 200.8	0.016	mg/L	1	0.0025	8/13/2020	NV00925
Selenium	EPA 200.8	ND	mg/L	1	0.0050	8/13/2020	NV00925
Sample Preparation							
Trace Metals Digestion	EPA 200.2	W200812-1		1		8/12/2020	NV00925

SPARKS

475 E. Greg Street, Suite 119
 Sparks, Nevada 89431
 tel (775) 355-0202
 fax (775) 355-0817
 EPA LAB ID: NV00925 - ELAP No: 2523

ELKO

1084 Lamoille Hwy
 Elko, Nevada 89801
 tel (775) 777-9933
 fax (775) 777-9933
 EPA LAB ID: NV00926

LAS VEGAS

3230 Polaris Ave. Suite 4
 Las Vegas, Nevada 89102
 tel (702) 475-8899
 fax (702) 622-2868
 EPA LAB ID: NV00932

Western Environmental Testing Laboratory

QC Report

QCBatchID	QCType	Parameter	Method	Result	Actual	% Rec	Units
QC20070927	Blank 1	Fluoride	EPA 300.0	ND			mg/L
		Nitrate Nitrogen	EPA 300.0	ND			mg/L
		Nitrite Nitrogen	EPA 300.0	ND			mg/L
QC20070954	Blank 1	Fecal Coliform (MPN)	IDEXX Quant/Col	ND			MPN/100ml
QC20070958	Blank 1	Total Coliform (MPN)	SM 9223B (Quant	ND			MPN/100ml
		Escherichia Coli (MPN)	SM 9223B (Quant	ND			MPN/100ml
QC20071067	Blank 1	Total Phosphorous as P	SM 4500-P E	ND			mg/L
QC20071080	Blank 1	Total Dissolved Solids (TDS)	SM 2540C	ND			mg/L
QC20071081	Blank 1	Total Dissolved Solids (TDS)	SM 2540C	ND			mg/L
QC20071159	Blank 1	Total Kjeldahl Nitrogen	EPA 351.2	ND			mg/L
QC20080541	Blank 1	Beryllium	EPA 200.7	ND			mg/L
		Boron	EPA 200.7	ND			mg/L
		Cadmium	EPA 200.7	ND			mg/L
		Chromium	EPA 200.7	ND			mg/L
		Copper	EPA 200.7	ND			mg/L
		Iron	EPA 200.7	ND			mg/L
		Manganese	EPA 200.7	ND			mg/L
		Nickel	EPA 200.7	ND			mg/L
		Zinc	EPA 200.7	ND			mg/L
QC20080563	Blank 1	Arsenic	EPA 200.8	ND			mg/L
		Lead	EPA 200.8	ND			mg/L
		Selenium	EPA 200.8	ND			mg/L

QCBatchID	QCType	Parameter	Method	Result	Actual	% Rec	Units
QC20070927	LCS 1	Fluoride	EPA 300.0	1.83	2.00	92	mg/L
		Nitrate Nitrogen	EPA 300.0	2.01	2.00	100	mg/L
		Nitrite Nitrogen	EPA 300.0	0.517	0.500	103	mg/L
QC20071067	LCS 1	Total Phosphorous as P	SM 4500-P E	0.273	0.250	109	mg/L
QC20071080	LCS 1	Total Dissolved Solids (TDS)	SM 2540C	158	150	105	mg/L
QC20071080	LCS 2	Total Dissolved Solids (TDS)	SM 2540C	148	150	99	mg/L
QC20071081	LCS 1	Total Dissolved Solids (TDS)	SM 2540C	147	150	98	mg/L
QC20071081	LCS 2	Total Dissolved Solids (TDS)	SM 2540C	148	150	99	mg/L
QC20071159	LCS 1	Total Kjeldahl Nitrogen	EPA 351.2	0.947	1.00	95	mg/L
QC20080541	LCS 1	Beryllium	EPA 200.7	0.994	1.00	99	mg/L
		Boron	EPA 200.7	0.947	1.00	95	mg/L
		Cadmium	EPA 200.7	0.965	1.00	97	mg/L
		Chromium	EPA 200.7	0.990	1.00	99	mg/L
		Copper	EPA 200.7	4.96	5.00	99	mg/L
		Iron	EPA 200.7	0.987	1.00	99	mg/L
		Manganese	EPA 200.7	0.989	1.00	99	mg/L
		Nickel	EPA 200.7	4.88	5.00	98	mg/L
		Zinc	EPA 200.7	0.983	1.00	98	mg/L
QC20080563	LCS 1	Arsenic	EPA 200.8	0.0465	0.050	93	mg/L
		Lead	EPA 200.8	0.0101	0.010	101	mg/L
		Selenium	EPA 200.8	0.0471	0.050	94	mg/L

QCBatchID	QCType	Parameter	Method	Duplicate Sample	Sample Result	Duplicate Result	Units	RPD
QC20070954	Duplicate 1	Fecal Coliform (MPN)	IDEXX Quant/Colilert	20070795-005	2.00	2.00	MPN/100ml	<1%

DF=Dilution Factor, RL = Reporting Limit (minimum 3X the MDL), ND = Not Detected <RL or <MDL (if listed)

Page 7 of 8

SPARKS

475 E. Greg Street, Suite 119
Sparks, Nevada 89431
tel (775) 355-0202
fax (775) 355-0817
EPA LAB ID: NV00925 - ELAP No: 2523

ELKO

1084 Lamoille Hwy
Elko, Nevada 89801
tel (775) 777-9933
fax (775) 777-9933
EPA LAB ID: NV00926

LAS VEGAS

3230 Polaris Ave. Suite 4
Las Vegas, Nevada 89102
tel (702) 475-8899
fax (702) 622-2868
EPA LAB ID: NV00932

QCBatchID	QCType	Parameter	Method	Duplicate Sample	Sample Result	Duplicate Result	Units	RPD
QC20071080	Duplicate 1	Total Dissolved Solids (TDS)	SM 2540C	20070802-003	1366	1340	mg/L	2 %
QC20071080	Duplicate 2	Total Dissolved Solids (TDS)	SM 2540C	20070803-003	718	828	mg/L	14 %
QC20071081	Duplicate 1	Total Dissolved Solids (TDS)	SM 2540C	20070804-003	828	838	mg/L	1 %
QC20071081	Duplicate 2	Total Dissolved Solids (TDS)	SM 2540C	20070821-003	1242	1252	mg/L	1 %

QCBatchID	QCType	Parameter	Method	Spike Sample	Sample Result	MS Result	MSD Result	Spike Value	Units	MS %Rec	MSD %Rec	RPD %
QC20070927	MS 1	Fluoride	EPA 300.0	20070793-005	ND	2.02	2.00	2	mg/L	98	97	1
		Nitrate Nitrogen	EPA 300.0	20070793-005	ND	2.16	2.16	2	mg/L	107	107	<1
		Nitrite Nitrogen	EPA 300.0	20070793-005	ND	0.560	0.558	0.5	mg/L	112	112	<1
QC20071067	MS 1	Total Phosphorous as P	SM 4500-P E	20070789-004	0.045	0.283	0.306	0.25	mg/L	95	104	8
QC20071159	MS 1	Total Kjeldahl Nitrogen	EPA 351.2	20070816-010	ND	0.900	1.02	1	mg/L	90	102	12
QC20080541	MS 1	Beryllium	EPA 200.7	20070359-015	ND	D 0.971	0.980	1	mg/L	97	98	<1
		Boron	EPA 200.7	20070359-015	0.210	1.15	1.17	1	mg/L	94	96	2
		Cadmium	EPA 200.7	20070359-015	ND	D 0.958	0.957	1	mg/L	96	96	<1
		Chromium	EPA 200.7	20070359-015	ND	D 1.02	1.02	1	mg/L	102	102	<1
		Copper	EPA 200.7	20070359-015	ND	D 5.34	5.38	5	mg/L	107	107	<1
		Iron	EPA 200.7	20070359-015	ND	D 1.00	1.00	1	mg/L	99	99	<1
		Manganese	EPA 200.7	20070359-015	ND	D 0.970	0.977	1	mg/L	96	96	<1
		Nickel	EPA 200.7	20070359-015	ND	D,U 4.87	4.89	5	mg/L	97	98	<1
		Zinc	EPA 200.7	20070359-015	ND	D 1.03	1.03	1	mg/L	102	102	<1
QC20080563	MS 1	Arsenic	EPA 200.8	20070359-015	0.3891	0.4360	0.4180	0.05	mg/L	94	58	4
		Lead	EPA 200.8	20070359-015	ND	0.0109	0.0092	0.01	mg/L	102	85	17
		Selenium	EPA 200.8	20070359-015	0.0073	0.0651	0.0591	0.05	mg/L	116	104	10

SPARKS

475 E. Greg Street, Suite 119
 Sparks, Nevada 89431
 tel (775) 355-0202
 fax (775) 355-0817
 EPA LAB ID: NV00925 - ELAP No: 2523

ELKO

1084 Lamoille Hwy
 Elko, Nevada 89801
 tel (775) 777-9933
 fax (775) 777-9933
 EPA LAB ID: NV00926

LAS VEGAS

3230 Polaris Ave. Suite 4
 Las Vegas, Nevada 89102
 tel (702) 475-8899
 fax (702) 622-2868
 EPA LAB ID: NV00932



WETLAB

WESTERN ENVIRONMENTAL TESTING LABORATORY *Specializing in Soil, Hazardous Waste and Water Analysis.*
 475 E. Greg Street #119 | Sparks, Nevada 89431 | www.WETLaboratory.com
 tel (775) 355-0202 | fax (775) 355-0817
 1084 Lamoille Highway | Elko, Nevada 89801
 tel (775) 777-9933 | fax (775) 777-9933
 3230 Polaris Ave., Suite 4 | Las Vegas, Nevada 89102
 tel (702) 475-8899 | fax (702) 776-6152

WETLAB Order ID. 20070821
 Sparks Control # _____
 Elko Control # _____
 LV Control # _____
 Report Due Date _____
 Page _____ of _____

Client Washoe County Community Services Department
 Address 1001 E. 9th Street
 City, State & Zip Reno, NV 89512
 Contact Dylan Menes
 Phone (775) 954-4626 Collector's Name _____
 Fax (775) 328-3699 PWS/Project Name Swan Lake
 P.O. Number _____ PWS/Project Number _____

Turnaround Time Requirements
 Standard
 5 Day* (25%) 72 Hour* (50%)
 48 Hour* (100%) 24 Hour* (200%)
 *Surcharges Will Apply

Samples Collected From Which State?
 NV CA
 Other

Report Results Via
 PDF EDD

Compliance Monitoring?
 Yes No Other _____

Report to Regulatory Agency?
 Yes No

Standard QC Required?
 Yes No

Email dmenes@washoecounty.us
 Billing Address (if different than Client Address)
 Company _____
 Address _____
 City, State & Zip _____
 Contact _____
 Phone _____ Fax _____
 Email dmenes@washoecounty.us

Analyses Requested

SAMPLE ID/LOCATION	DATE	TIME	PRES TYPE	NO. OF CONTAINERS	E. Coli / Total Coliform, Fecal Coliform	TDS	Total Phosphorus	Total Nitrogen	Nitrite/ Nitrate / Total Kjeldahl Nitrogen	Arsenic / Boron	Beryllium/ Cadmium/ Chromium/Copper	Lead/ Nickel	Iron/ Fluoride	Manganese/Selenium/ Zinc	Spl. No.
--------------------	------	------	-----------	-------------------	--	-----	------------------	----------------	--	-----------------	-------------------------------------	--------------	----------------	--------------------------	----------

SAMPLE ID/LOCATION	DATE	TIME	PRES TYPE	NO. OF CONTAINERS	E. Coli / Total Coliform, Fecal Coliform	TDS	Total Phosphorus	Total Nitrogen	Nitrite/ Nitrate / Total Kjeldahl Nitrogen	Arsenic / Boron	Beryllium/ Cadmium/ Chromium/Copper	Lead/ Nickel	Iron/ Fluoride	Manganese/Selenium/ Zinc	Spl. No.
Swan Lake - Compton	7/23/20	1525	Misc.	SW	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
Swan Lake - Pompe	7/23	1500	Misc	SW	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
Swan Lake - Jean	7/23	1450	Misc	SW	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
Am-Flats - Spigot	7/23	1435	Misc	SW	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	

Instructions/Comments/Special Requirements:

Sample Matrix Key** DW = Drinking Water WW = Wastewater SW = Surface Water MW = Monitoring Well SD = Solid/Sludge SO = Soil HW = Hazardous Waste OTHER: _____

*SAMPLE PRESERVATIVES: 1=Unpreserved 2=H2SO4 3=NaOH 4=HCl 5=HNO3 6=Na2S2O3 7=ZnOAc+NaOH 8=HCl/VOA Vial

Temp	Custody Seal	# of Containers	DATE	TIME	Samples Relinquished By	Samples Received By
5.3°C	Y N None	20	7/23/20	1620	<i>[Signature]</i>	<i>[Signature]</i>
°C	Y N None					
°C	Y N None					
°C	Y N None					

WETLAB'S Standard Terms and Conditions apply unless written agreements specify otherwise. Payment terms are Net 30.

Client/Collector attests to the validity and authenticity of this (these) sample(s) and, is (are) aware that tampering with or intentionally mislabeling the sample(s) location, date or time of collection may be considered fraud and subject to legal action (NAC445.0636). _____ initial
 To the maximum extent permitted by law, the Client agrees to limit the liability of WETLAB for the Client's damages to the total compensation received, unless other agreements are made in writing. This limitation shall apply regardless of the cause of action or legal theory pled or asserted. _____ initial
 WETLAB will dispose of samples 90 days from sample receipt. Client may request a longer sample storage time for an additional fee. 301.2E
 Please contact your Project Manager for details. _____ initial